

Resolution No. 31-14

**A RESOLUTION OF THE VILLAGE OF EAST DUNDEE,
COOK AND KANE COUNTIES, ILLINOIS, TO AWARD A CONTRACT TO BURY
UTILITY LINES
TO RAY'S ELECTRICAL & BORING SERVICE**

WHEREAS, the Village of East Dundee, Cook and Kane Counties, Illinois (the "Village") is a duly organized and validly existing home-rule municipality created in accordance with the Constitution of the State of Illinois of 1970 and the laws of the State; and,

WHEREAS, in order to provide reconnection services for the properties that a new transformer will energize, the Village must bury the utility lines located on Third Street in the Village; and,

WHEREAS, the Village has received a quote from Ray's Electrical & Boring Service for the burial of the utility lines; and,

WHEREAS, it has been determined that in order to proceed prior to the onset of winter, it is in the best interests of the Village that the contract for the burial of the utility lines be awarded to Ray's Electrical & Boring Service and that the bidding requirements be waived pursuant to Section 34.01(B) of the Code of the Village of East Dundee.

NOW THEREFORE, BE IT RESOLVED, by the President and Board of Trustees of the Village of East Dundee, Cook and Kane Counties, Illinois, as follows:

Section 1: The foregoing preambles are hereby adopted as if fully restated herein.

Section 2: That the bidding requirements are waived pursuant to Section 34.01(B) of the Code of the Village of East Dundee and the contract for the burial of the utility lines on Third Street is awarded to Ray's Electrical & Boring Service in an approximate amount of \$122,712.21 and the Village President and Village Clerk are hereby authorized to execute the *Estimate*, attached hereto and made a part hereof by reference as Exhibit A, on behalf of the Village.

Section 3: That this resolution shall be in full force and effect from and after its passage and approval according to law, and waiving the bidding requirements by a two-thirds vote of the members of the Village Board of Trustees.


PASSED this 27th day of Oct, 2014, pursuant to a roll call vote as follows:

AYES: Trustees Lynam, Skillicorn, Selep and Wood


NAYS: \emptyset

ABSENT: Trustees Gorman and Ruffalo

APPROVED this 27th day of Oct, 2014



Lael Miller, Village President

Attest: 

Heather Maieritsch, Village Clerk

MEMORANDUM

TO: ROBERT SKURLA, VILLAGE ADMINISTRATOR
FROM: JIM KELLY, DIRECTOR OF PUBLIC WORKS & BUILDING JK
SUBJECT: REMOVAL OF AERIAL LINES ON THIRD STREET AND HILL STREET
DATE: 10/20/2014
CC: LINDA BLACKERBY, FINANCE DIRECTOR, TREASURER

Bob,

Recently, we discovered that the proposed location for a transformer (we do not need an easement agreement) which will eventually provide underground electrical along with other low voltage wiring, will be located in the Village Right Of Way. To accomplish this future work, the lines on Third Street will be buried. During a meeting with ComEd last week, they informed us that the village will incur the costs to bury all lines and eventually provide reconnection services for all properties that this transformer will energize. These businesses include The Anvil Club, 319 Meier (green building owned by Tom Roeser) Diamond Jim's, Reinke property, future Village Hall, New Police Facility and possibly several residences on the 100 block of Barrington Avenue.

Attached is a proposal from Ray's Electrical Service for this time sensitive work. I am recommending we move forward with this work as a "sole source" provider. This is a necessary phase one project combining several locations and the burial of all piping to insure the correct sizing and connections for our properties, including the relocation of the Hill Street lift station.

Ray's Electrical has provided accurate and precision directional boring as well as having a good working relationship with ComEd. Weather is of course a concern and ComEd has agreed to place the transformer the week of November 17th provided the boring has been completed.

RAY'S ELECTRICAL & BORING SERVICE

37W904 US HIGHWAY 20
ELGIN, IL 60124

(847)214-2944
ray@rayselectrical.com



ESTIMATE

ADDRESS

Village of East Dundee
120 Barrington Avenue
East Dundee, IL 60118

ESTIMATE NO. 1070
DATE 10/17/2014
EXPIRATION DATE

ACTIVITY	QTY	RATE	AMOUNT
Re: THE VILLAGE OF EAST DUNDEE - The aerial removal of utility cables for future expansion for underground utilities			
Directional Boring	1	122,712.21	122,712.21
Installation of underground raceway for ComEd and ATT Utility Companies. Preparation for the removal of aerial cables and utility poles along Hill Street and 3rd Street.			
300' of single 3" conduit- Hill Street			
300' of double 4" conduit- 3rd Street			
120' of double 3" Com Ed -3rd St			
120' of single 4" ATT- 3rd St			
330' of double 3" Com Ed- 3rd St			
330' of single 4" Att- 3rd St			
Services			
Excavate and install CA6 Sub-Base and ComEd required C5293A Transformer Pad; (8) 3.5" concrete filled per utility companies spec and guidelines.			
Services			
Sawcut, Removal and Haul off of spoils to be discarded by the city of east Dundee pertaining to area above underground creek; We have included concrete encasement of approximately 80 linear feet.			

Thank you for the opportunity to service your Electrical needs.

ACTIVITY	QTY	RATE	AMOUNT
----------	-----	------	--------

Notes:

1. Any additional work will be marked up as an extra.
2. All concrete/asphalt openings are \$250.00 each if applicable.
3. All 4" cores are \$250.00 each if applicable.
4. Spoils required to be removed will be by other.
5. Any landscape restoration will be paid by other.
6. This Bid is based on soil containing clay or black dirt; rock, concrete or any unforeseen obstructions will be marked up as an extra.
7. Permits and Fees will be by other.
8. Any additional pot holes located in asphalt, concrete or like areas will be marked as an extra at a rate of \$250.00 each additional pot hole if applicable. Concrete pour and finishing will be by other.
9. This estimate does not include frost like conditions.
10. Rays Electrical & Boring Service will not be responsible or held liable for any unmarked and/or private utilities.
11. Julie will be notified prior to starting any underground work.
12. This proposal is valid for 30 Days.
13. This Bid does not include cable.
14. The removal of cable and utility poles will be by Utility Companies not by Rays Electrical Service

TOTAL

\$122,712.21

Accepted By

Accepted Date

Thank you for the opportunity to service your Electrical needs.



Village Transformer on Third St.

Joseph Heinz

to:

'Jim Kelly'

10/15/2014 11:37 AM

Cc:

""Tim Wilson""

Hide Details

From: "Joseph Heinz" <jheinz@glheinzing.com>

To: ""Jim Kelly"" <JKelly@eastdundee.net>,

Cc: ""Tim Wilson"" <TWilson@eastdundee.net>

Security:

To ensure privacy, images from remote sites were prevented from downloading. Show

Images

History: This message has been forwarded.

2 Attachments



image001.gif image002.jpg

Jim,

From what I can gather, the easterly back of curb is approximately 12 feet from the easterly right-of-way line. The elevated concrete patio area is approximately 14.5 feet from the back of curb. I recommend that the depressed curb be removed and replaced with barrier curb in front of the proposed pad. The pad should be placed at least 2 feet behind the curb and protected with bollards. Please let me know if you have any other questions.

Regards,

Joseph D. Heinz, P.E., P.L.S.

Gerald L. Heinz & Associates, Inc.
Consulting Engineers & Land Surveyors

206 North River Street
East Dundee, Illinois 60118
Phone: 847.426.4535
Fax: 847.426.4584



Gerald L. Heinz & Associates, Inc.

Consulting Engineers and Architects

Job: AD - 1974
Sheet No: 1 of 1
Calculated By: JDH Date: 10/16/14
Checked By: _____ Date: _____
Scale: 1" = 10'

