



**BUILDING DEPARTMENT
PERMIT REQUIREMENTS**

**LIQUID PETROLEUM
GAS TANKS
(PROPANE)**

REQUIREMENTS:

1. A completed permit application
2. A plat of survey indicating the following:
 - location of all tanks
 - number and size of all tanks
 - distance from any principle structure

GENERAL GUIDELINES:

- Liquefied petroleum gas shall be limited to any one installation not exceeding a water capacity of 500 gallons without a special permit approved by the fire code official. Storage outside of buildings shall be not less than 10' feet from any openings in buildings or 10' feet from any combustible material and a minimum of 20' feet from a motor vehicle fuel dispenser.

NOTE: All installations of L. P. Gas Tanks are to be installed per the 2012 International Fire Code, Chapter 61: Liquefied Petroleum Gases Code with a special use permit.

REQUIRED INSPECTIONS:

- Final

PERMIT FEES:

The fee for this permit shall be \$150.00 for commercial.

Note: Fees for plan review may be applicable.

If you have any questions please contact
the West Dundee Building Department at (847) 551-3805

CONTACT J.U.L.I.E.
48 Hours Before You Dig!
1-800-892-0123
Excluding Saturday, Sundays & Holidays

